

Gallatin Department of Electricity Approved Meter Bases

GDE

P.O.Box 1555
Gallatin, TN. 37066
(615) 452-5152
(615) 452-6060 Fax

Self Contained

Size	Phases	Type	Milbank	Durham	Siemens	Eaton
200 Amp	Single	OH	U7021-DL-TG-BL	RS213N	UAT3 / HQU4	UTRS202BCH
200 Amp	Single	UG	U1980-0-BL	UTRS223A	UAS8/UAS9 / HQW4	UTRS223ACH
225 Amp	Single	House Module			WCL204081T1RJ	
320 Amp	Single	OH	U1079-R-BL		HQST 4	UTH4300TCH
320 Amp	Single	UG	U1797-0-K3L-K2L-BL		HQDSW/SWD 4	UTH43369UCH
320 Amp	Single	OH/UG	U2448-x	H4330T		UTH4330TCH
200 Amp	Three	OH/UG	U7423-RXL	H7213T	HQND 5	
200 Amp	Three	OH/UG	U9701-RRL-BL		HQST 7 / HQW 7	
225 Amp	Three	Module			WCL2040B2T1RJ	
225 Amp	Three	Module			WCL2442B3T1RJ	
320 Amp	Three	OH/UG	U2120-x	UT-H7330-U	HQST 7	
320 Amp	Three	OH/UG	U2594-Y		HQDSW/SWD 7	
600 Amp	Three	OH/UG	U4667-xt-9506		(K-7T) 9817-9506	CH9506K7

Instrument Rated

Size	Terminals		Milbank	Durham	Siemens	Meter Devices
20 Amp *	8	See Note 5	UC7235-RL	R6821-8K	9804-8542	
20 Amp **	13		UC7461-RL	STS13-2K	9837-8512	W110U54522-5

Pedestal Service Entrance

Size	Terminals		Midwest			
200 Amp	4		R281C1P6H			

* 8 Terminal Base Requires Automatic Bypass Switch

** 13 Terminal Base Requires test switch Durham # 1058 or Milbank # TS10-0111 (10 Pole)

Specifications and Notes

- 1) ALL NON-APPROVED METER BASES WILL NOT BE ENERGIZED BY GDE
- 2) UL Approved with Label
- 3) Steel Construction
- 4) All Instrument Rated bases shall have shorting ability to remove meter
- 5) Also used on, 600 Amp and above, single phase service.
- 6) ALL 600 Amp and above services REQUIRE advance notice to be given to GDE Meter Department. Call 615-527-7006 or 615-527-7005.

Instrument Transformers

All CT and PT's shall be provided by GDE.

CT cabinet size shall be 36 x 36 x 12 with a 3/4 inch plywood backing for mounting of Instrument Transformers. Steel or aluminum construction.

CT cabinet must have provisions for a padlock.

Single Phase - Electrician shall provide 5 wires, (BLACK, RED, BROWN, ORANGE, WHITE)

3 Phase - Electrician shall provide 7 wires (BLACK, RED, BLUE, BROWN, ORANGE, YELLOW, WHITE)

No marking tape shall be used on wires.

All CT and PT wires shall be #12 copper conductor.

Multi Ganged, Stacked meterbases, and Module Bases are APPROVED on a case by case bases.

Submit information to:

rpryor@gdetn.com

bthornton@gdetn.com